



Recommended Values at When to Change OptiShield Products

Product Type	pH (Installed-new solution)	Change Solution When pH is:	Free Chlorine Level (Installed-new solution)	Change Solution When Free Chlorine is:
OPTISHIELD	10.4	<9	N/A	N/A
OPTISHIELD Plus	10.5	<9	71 ppm	<5 ppm
OPTISHIELD II	7.7	<7.1	N/A	N/A
OPTISHIELD II Plus	7.8	<7.1	71 ppm	<5 ppm

Opti Temp Inc. makes the below product recommendation available only for the convenience of the customer

Portable pH Tester Meter: Cole Palmer/Oakton Part #: 35634-10

Portable pH Tester Meter & Calibration Kit: Cole Palmer/Oakton Part #: 35634-70

Chlorine / Bromine Test Kit, LaMotte Part #: 3624

Products Available at Associated Web Site, Model Number Might Change at Any Time

<https://www.coleparmer.com/>

<http://www.lamotte.com/en/browse/3624-01.html>